



**NOTES:**

1. Diameter of Drop Pipe Shall Not Be Less than the Main Diameter.
2. The Entire Exterior Drop Structure Shall Be Constructed of Class 50 Ductile Iron Pipe and Fittings, Beginning with the Drop "T" Fitting
3. Use 1/2-inch Diameter Expansion Type Stainless Steel Cinch Bolts with Stainless Steel Washers and Nuts.



## Sewer Extension Exterior Drop Connection

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-S-006

Date: 10/16/2020

Scale: Not To Scale

Drawn By: Staff