



Notes:

1. Diameter of the drop pipe shall not be less than the main diameter.
2. The interior drop connection shall be constructed with SDR 26 PVC and fittings beginning with the "T" fitting.
3. Use 1/2-inch diameter expansion type stainless steel cinch bolts with stainless steel washers and nuts.



Sewer Extension Interior Fittings Drop Connection Beginning with the Drop "T" Fitting

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-S-007

Date: 10/16/2020

Scale: Not To Scale

Drawn By: Staff