



Notes:

1. Trenches requiring shoring ebracing, dimensions shall be taken from inside face of the shoring and bracing compacted to minimal 95% proctor density for Class I material.
1. Warning tape and tracer wire to be provided per specifications
2. Embedment material must be Class I (no. 67 or no. 78 washed stone)
3. Only for depths 3' to 10'



Pipe Trench Bedding for Sewer Mains

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-S-008
Date: 10/16/2020
Scale: Not To Scale
Drawn By: Staff