



Notes:

1. Within the city limits of Sanford or within the Northview Fire District, the 2½" nozzles shall have City of Sanford threads, as shown above (3.112" x 8 threads per inch). All other locations shall be National Standard Thread.



## 2.5" Hydrant Nozzle Threads

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-W-010

Date: 02/11/2020

Scale: Not To Scale

Drawn By: Staff