



Notes:

1. Hydrant tag shall be corrosion resistant solid brass; Pollard Water sku PP69242 or approved equal.
2. The City of Sanford Engineering Dept. shall assign the unique hydrant identifier. Format shall be XXXX-1234, where XXXX is a street name abbreviation, up to four alpha characters, and 1234 is a four-digit numerical identifier.



## Hydrant Tag

City of Sanford Engineering Dept - P.O. Box 3729 - Sanford, NC 27331

Dwg. No. SD-W-011

Date: 04/02/2020

Scale: Not To Scale

Drawn By: Staff