



## GREASE INTERCEPTORS

### Existing Establishments - Options

1. Install a default tank (1000 gal) per city specifications.
2. Write a letter stating that there is no cooking, no grease and no dishwashing, etc.
3. Get an engineer to design and submit design criteria with engineering seal.
4. If existing system is adaptable in the city's opinion - make adjustments on city's recommendations.

### New Establishments - Options

1. Install a default tank (1000 gal) per city specifications.
2. Write a letter stating that there is no cooking, no grease and no dishwashing, etc.
3. Get an engineer to design and submit design criteria with engineering seal.

#### \*\*NOTE:

The discharger is required to meet ordinance discharge limits of 100 parts/million under all options.